



3930-FM-BSDW0200 Rev. 5/2020



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF SAFE DRINKING WATER

DRINKING WATER WARNING DO NOT DRINK THE WATER

NO BEBA EL AGUA

ESTE INFORME CONTIENE INFORMACIÓN IMPORTANTE ACERCA DE SU AGUA POTABLE. HAGA QUE
ALGUIEN LO TRADUZCA PARA USTED, O HABLE CON ALGUIEN QUE LO ENTIENDA.

Conneaut Lake Borough has high levels of Arsenic.

Sample results received on 6/25/26 showed UNDETERMINED levels of ARSENIC.
This level MAY EXCEED THE LEVEL of .01 mg/L. ARSENIC
in drinking water at this level may be a serious health concern

What should I do?

DO NOT DRINK THE WATER. Use bottled water or alternative sources for drinking, cooking, or food preparation until further notice. Throw away ice cubes if made with tap water.

DO NOT BOIL THE WATER. Boiling, freezing, filtering, or letting water stand does not reduce the ARSENIC level. Excessive boiling can make the ARSENIC more concentrated, because ARSENIC remains behind when the water evaporates.

If you have specific health concerns, you may wish to consult your doctor.

What happened? What is being done?

ARSENIC. We'll let you know when the amount of ARSENIC is again below the limit.

THERE WAS A PROBLEM AT THE TREATMENT PLANT, THAT REMOVES ARSENIC FROM OUR WATER
THE PROBLFM HAS BEEN CORECTED 6-25-26 THE WATER THAT BYPASSED THE ARSENIC
TREATMENT IS BEING FLUSHED FROM THE SYSTEM AND WE ARE TESTING THE LEVELS TO
MAKE SURE WE ARE IN COMPLIANCE WITH DEP REQUIREMENTS. THERE WILL BE WATER
AVAILABLE AT THE FILTER BUILDING ON 2ND STREET. BRING A CONTAINER

We anticipate resolving the problem by 6/27/26 12:00PM.

For more information, please contact:
JULIE MCVAY
CONNCAUT LAKE BOROUGH
MUNICIPAL AUTHORITY
at 814-382-9323

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by CARL MCLEAN.

PWS ID#: _____

Date distributed: 6/25/2026